

# GREEN LABEL PLUS

INDOOR AIR QUALITY TESTING PROGRAM  
THIS CERTIFIES THAT

**Milliken & Company**

Address: PO Box 1926, 920 Milliken Road M-620,  
Spartanburg, SC 29304, United States

HAS MET THE REQUIREMENTS OF THE CARPET AND RUG INSTITUTE'S  
GREEN LABEL PLUS PROGRAM FOR CATEGORY:

## A-2 Pressure Sensitive

Adhesive Applied in Mass Per Surface Area: 6.84 g of product per 0.0361 m<sup>2</sup>

Private Office Range of Total VOCs:  
0.5 mg/m<sup>3</sup> or less

School Classroom Range of Total VOCs:  
0.5 mg/m<sup>3</sup> or less

Product Type: Single Part Wet Adhesive

Description: Milliken Mosaic 95

Joe W. Yarbrough, President  
The Carpet and Rug Institute, Inc.

Certification Date: June 17, 2021  
Expiration Date: March 31, 2023

To view all GLP-Certified products visit [www.carpet-rug.org/glpproducts](http://www.carpet-rug.org/glpproducts).



## GLP100259

This product complies with  
California DPH Section 01350  
Version 1.2

A USGBC® recognized third  
party certification program  
for LEED v4.1 EQ Credit  
Low-Emitting Materials.

