

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **TEST REPORT**

Client : Mil	Milliken (Australia) Pty Ltd			Test Number : Issue Date :		23-003740	
171 Briens Road Northmead NSW 2152						27/10/2023	
				Print Date :	:	27/10/2023	
				Order Number	r :	6701505098	
Sample Desci	ription	Clients Ref :	"Colourweave Base (Multi-colour/Multi - Design)"				
		Tufted loop pile carpet tile with WellBAC comfort (PVC free) backing					
End Lion · Electring							

End Use : Flooring Nominal Composition : 100% Nylon Nominal Mass per Unit Area/Density : 3.4kg/m2 Nominal Thickness : 8.5mm



308035

66743

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

Jula

Fiona McDonald



Page 1 of 2

MICHAEL A. JACKSON B.Sc.(Hons)

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

## **TEST REPORT**

Client :	Milliken (Australia) Pty Ltd	Test Number	:	23-003740
	171 Briens Road	Issue Date	:	27/10/2023
	Northmead NSW 2152	Print Date	:	27/10/2023
		Order Numbe	r :	6701505098

AS ISO 9239.1-2003

## Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source

Date of Sample Arrival			14-09-2023			
	Date Tested		26-10-2	023		
	CHF Value	1	2	3	Mean	
	Length	6.2	-	-	-	kW/m²
	Width	4.4	4.8	4.8	4.7	kW/m²
	HF-30 Value	1	2	3	Mean	
	Length	6.2	-	-	-	kW/m²
	Width	5.2	5.0	5.4	5.2	kW/m²
	Smoke Value	1	2	3	Mean	
	Length	183	-	-	-	%.min
	Width	223	219	224	222	%.min

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

308035

66743

C Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

12

Fiona McDonald APPROVED SIGNATORY





Page 2 of 2

MICHAEL A. JACKSON B.Sc.(Hons)